

Elevations

- Emergency escape and rescue windows. CBC 310.4
- Window well requirements. CBC 310.4
- Finished sill height 44" maximum a.f.f. CBC 310.4
- Note exterior finish. CBC 106.3.3
- Label natural and finished grades. CBC 106.3.3
- Exit door width and height. CBC 1004.6, 1004.7
- Door landing required. CBC 1004.10
- Door threshold. CBC 1004.9
- Number of exits (basements/above 2nd story). CBC 1003.1
- Projections. CBC 503.2.1, 705
- Height/number of stories. T-5-B
- Bracing. CBC 2326.11.3. No let-in. Table 23-I-W
- Safety glazing. CBC 2406, 1004.11